



# Concentrating Solar Power: Current Cost and Future Directions

Craig Turchi  
CSP Systems Analysis Task Leader  
Thermal Systems R&D Group

[craig.turchi@nrel.gov](mailto:craig.turchi@nrel.gov)

May 30, 2017



- NREL's System Advisor Model (SAM)
- CSP costs
- CSP research directions
  - Molten salts and other heat storage media
  - Advanced power cycles
  - Plant configuration and value optimization



The System Advisor Model (SAM) is a performance and financial model designed to facilitate decision making for people involved in the renewable energy industry.

SAM 2017.1.17

Choose a performance model, and then choose from the available financial models.

- Photovoltaic (detailed)
- Photovoltaic (PVWatts)
- High concentration PV
- Wind
- Biomass combustion
- Geothermal
- Solar water heating
- Generic system
- CSP parabolic trough (physical)
- CSP parabolic trough (empirical)
- CSP power tower molten salt
- CSP power tower direct steam
- CSP linear Fresnel molten salt
- CSP linear Fresnel direct steam
- CSP dish Stirling
- CSP generic model
- CSP integrated solar combined cycle
- Process heat parabolic trough
- Process heat linear direct steam

SAM 2017.1.17

File Add Molten salt power tower

Tower (salt), Single owner

Location and Resource

System Design

Heliostat Field

Tower and Receiver

Power Cycle

Thermal Storage

System Control

System Costs

Lifetime

Financial Parameters

Time of Delivery Factors

Incentives

Depreciation

Simulate >

Parametrics Stochastic

P50 / P90 Macros

**Design Point Parameters**  
The design point parameters determine the nominal ratings of each part of the power tower system. After specifying the design point parameters here, you can specify details of each component of the system on the Heliostat Field, Tower and Receiver, Thermal Storage, and Power Cycle input pages.

**-Heliostat Field-**

Design point DNI	950 W/m <sup>2</sup>
Solar multiple	2.4
Receiver thermal power	670 MWt
Heliostat field multiple	1

**-Tower and Receiver-**

HTF hot temperature	574 °C
HTF cold temperature	290 °C

**-Thermal Storage-**

Full load hours of storage	10 hours
Solar field hours of storage	4.16667 hours

**-Power Cycle-**

Design turbine gross output	115 MWe
Estimated gross to net conversion factor	0.9
Estimated net output at design (nameplate)	104 MWe
Cycle thermal efficiency	0.412
Cycle thermal power	279 MWt



# NREL 2016 CSP Cost Survey

- Questioned CSP developers and stakeholders regarding the current cost of CSP
- Values used to keep SAM's cost inputs up-to-date
- Separate sections for power tower, parabolic trough, and linear Fresnel systems

Survey	Number of respondents	Total questions	Questions with $\geq 3$ responses
Power Tower	20*	32	32 (100%)
Parabolic Trough	20*	26	15 (58%)
Linear Fresnel	0	29	0

\* The 20 respondents were not all the same for each technology




# SAM Changes: Power Towers

Power Tower (Molten Salt and DSG)		SAM 2016	SAM 2017	Responses	Comments/Justification
Site Improvements	\$/m2	16	no change	11	
Heliostat Field	\$/m2	170	145	17	Wide variability in responses
Tower cost formula			no change	11	
Receiver cost formula				10	Reduce DSG by about 10%, MS by lesser amount
Receiver reference cost (MS)	\$	110,000,000	103,000,000		
Receiver cost scaling exponent		0.7	no change		
Receiver reference cost (DSG)	\$	55,402,800	48,800,000		
Receiver cost scaling exponent		0.7	no change		
Thermal energy storage	\$/kWh-t	26	24	11	
Power cycle	\$/kWe	1190	1100	12	
Balance of plant	\$/kWe	340	no change	11	
Contingency	%	7	no change	15	
EPC & Owners Cost	%	11	13	13	
Sales Tax	%	5	no change	13	5% applied to 80% of direct costs
O&M Fixed cost by capacity (MS)	\$/kW-yr	66	no change	7	
O&M Fixed cost by capacity (DSG)	\$/kW-yr	50	55	6	
Variable cost O&M (both)	\$/MWh	4	3.5	10	
Property Tax	%	0	no change	7	reviewers recommend 0-1.2%, but left at 0% to match other SAM models
Insurance	%	0.5	no change	7	
Min. turbine operation	%	25	20	10	
Max. turbine over design	%	105	no change	12	



# Heliostat Field Cost

**Question: Current installed cost for heliostat field = 170/m<sup>2</sup>?**



➤ New SAM value = \$145/m<sup>2</sup>



# CSP Costs: SAM 2016 vs. SAM 2017

SAM Model with default values	Total Overnight Installed Cost (\$/kW)		
	SAM 2016.03.14	SAM 2017.01.17	% change
Physical Trough (6 h thermal storage)	6,705	6,065	-9.5%
Molten Salt Tower (10 h thermal storage)	7,365	6,800	-7.7%
Direct-Steam Tower (no thermal storage)	4,710	4,170	-11.5%

- Costs assume construction in the southwest region of the United States
- Applying SunShot financial assumptions (see *On the Path to SunShot*, NREL/TP-5500-65688, 2016), the lowest levelized cost of energy corresponds to the molten salt power tower with a value of approximately **110 USD/kWh**.



# SunShot CSP Gen3 Technology Roadmap

	Collector Field		
	<ul style="list-style-type: none"> <li>• Cost &lt;\$75/m<sup>2</sup></li> <li>• Concentration ratio &gt;50</li> </ul>	<ul style="list-style-type: none"> <li>• Operable in 35-mph winds</li> </ul>	<ul style="list-style-type: none"> <li>• Optical error &lt;3.0 mrad</li> <li>• 30-year lifetime</li> </ul>
	Molten Salt	Falling Particle	Gas Phase
Receiver	<ul style="list-style-type: none"> <li>• Similarities to prior demonstrations</li> <li>• Allowance for corrosive attack required</li> </ul>	<ul style="list-style-type: none"> <li>• Most challenging to achieve high thermal efficiency</li> </ul>	<ul style="list-style-type: none"> <li>• High-pressure fatigue challenges</li> <li>• Absorptivity control and thermal loss management</li> </ul>
Material & Support	<ul style="list-style-type: none"> <li>• Potentially chloride or carbonate salt blends; ideal material not determined</li> <li>• Corrosion concerns dominate</li> </ul>	<ul style="list-style-type: none"> <li>• Suitable materials readily exist</li> </ul>	<ul style="list-style-type: none"> <li>• Minimize pressure drop</li> <li>• Corrosion risk retirement</li> </ul>
Thermal Storage	<ul style="list-style-type: none"> <li>• Direct or indirect storage may be superior</li> </ul>	<ul style="list-style-type: none"> <li>• Particles likely double as efficient sensible thermal storage</li> </ul>	<ul style="list-style-type: none"> <li>• Indirect storage required</li> <li>• Cost includes fluid to storage thermal exchange</li> </ul>
HTF to sCO <sub>2</sub> Heat Exchanger	<ul style="list-style-type: none"> <li>• Challenging to simultaneously handle corrosive attack and high-pressure working fluid</li> </ul>	<ul style="list-style-type: none"> <li>• Possibly greatest challenge</li> <li>• Cost and efficiency concerns dominate</li> </ul>	<ul style="list-style-type: none"> <li>• Not applicable</li> </ul>
	Supercritical CO <sub>2</sub> Brayton Cycle		
	<ul style="list-style-type: none"> <li>• Net thermal-to-electric efficiency &gt; 50%</li> </ul>	<ul style="list-style-type: none"> <li>• Power-cycle system cost &lt; \$900/kW<sub>e</sub></li> </ul>	<ul style="list-style-type: none"> <li>• Dry-cooled heat sink at 40° C ambient</li> <li>• Turbine inlet temperature ≥ 700°C</li> </ul>



# Molten Salt Options for Higher Temperature Operation

Salt	Melting Point (C)	Maximum Temp (C)	Heat Capacity (J/g-K)	Density (kg/L)	Viscosity (cP)	Relative $\rho^*C_p$ (-)
Solar Salt ( $\text{NaNO}_3/\text{KNO}_3$ )	220	~600	1.55	1.71	1.0	1.00
$\text{KNO}_3$	334	~650?	1.39	1.78	-	0.93
$\text{KCl/MgCl}_2$	426	>900	1.1	1.97	1.9	0.82
$\text{KCl/NaCl/MgCl}_2$	385	>900	1.1	1.94	1.6	0.81
$\text{ZnCl}_2/\text{KCl/NaCl}$	199	>800	0.92	2.08	4.5	0.72
$\text{Na}_2\text{CO}_3/\text{K}_2\text{CO}_3/\text{Li}_2\text{CO}_3$	398	~800	1.83	1.99	8.3	1.37

Physical properties estimated/measured near 600°C for comparison

Data sources:

- Solar salt: SQM solar thermal salts factsheet
- Mg chlorides: ORNL/TM-2006/69; Serrano-Lopez et al. (2013); Gowtham Mohan et al. (2017 submitted)
- Zn chlorides: University of Arizona (private correspondence)
- Carbonates: An et al. (2016)



# New Molten Salt Benefits/Challenges

Salt	Primary Benefit vs Solar Salt	Primary Challenges
$\text{KNO}_3$	<ul style="list-style-type: none"> <li>Slightly better thermal stability (600-650°C)</li> </ul>	<ul style="list-style-type: none"> <li>Slightly higher <math>T_{\text{mp}}</math></li> <li>Slightly higher cost</li> </ul>
$\text{KCl/MgCl}_2$	<ul style="list-style-type: none"> <li>Lower salt cost</li> <li>Better thermal stability</li> </ul>	<ul style="list-style-type: none"> <li>Higher <math>T_{\text{mp}}</math></li> <li>Lower <math>\rho^*C_p</math> (i.e., larger tanks)</li> <li>Corrosion</li> </ul>
$\text{KCl/NaCl/MgCl}_2$	<ul style="list-style-type: none"> <li>Lower salt cost</li> <li>Better thermal stability</li> </ul>	<ul style="list-style-type: none"> <li>Higher <math>T_{\text{mp}}</math></li> <li>Lower <math>\rho^*C_p</math></li> <li>Corrosion</li> </ul>
$\text{ZnCl}_2/\text{KCl/NaCl}$	<ul style="list-style-type: none"> <li>Slightly lower <math>T_{\text{mp}}</math></li> <li>Better thermal stability</li> </ul>	<ul style="list-style-type: none"> <li>Lower <math>\rho^*C_p</math></li> <li>Corrosion</li> <li>Measureable vapor pressure</li> <li>Slightly higher salt cost</li> </ul>
$\text{Na}_2\text{CO}_3/\text{K}_2\text{CO}_3/\text{Li}_2\text{CO}_3$	<ul style="list-style-type: none"> <li>Higher <math>\rho^*C_p</math> (smaller tanks)</li> <li>Better thermal stability</li> </ul>	<ul style="list-style-type: none"> <li>Higher <math>T_{\text{mp}}</math></li> <li>Corrosion</li> <li>High salt cost (<math>\text{Li}_2\text{CO}_3</math>)</li> </ul>

➤ Laboratory testing indicates Cl corrosion can be controlled if high purity is maintained in the salt melt




# Falling Particle Power Tower Systems

## Advantages

- No freezing concerns
- No trace heating
- Thermally stable particles
- Direct heating of particles allows for high flux/concentration ratios
- Direct storage of inexpensive particles
- Particle handling, heat exchange, and storage techniques well established

## Challenges


- Less established within CSP industry
- Particle durability, attrition (dust emission)
- Receiver efficiency via convective/radiative and particle losses
- Increase particle/wall heat transfer
- Particle-to-sCO<sub>2</sub> heat exchanger at 700°C, 20 MPa





# CSP Power Cycle Development

- The **supercritical-CO<sub>2</sub> Brayton cycle** promises higher efficiency and lower installed cost versus to existing superheated steam cycle
- \$100 million cost-shared project is to build and demonstrate a 10 MW<sub>e</sub> system in Texas
- Cycle performance gains are more pronounced at higher temperatures; U.S. DOE program is targeting 700°C turbine inlet temperature



[Home](#) » DOE Announces \$80 Million Investment to Build Supercritical Carbon Dioxide Pilot Plant Test Facility


## DOE Announces \$80 Million Investment to Build Supercritical Carbon Dioxide Pilot Plant Test Facility

October 17, 2016 - 11:39am




# System Operation/Dispatch Optimization

## Simple



## Optimized



Metric	Simple	Optimized
Annual energy (year 1)	301,600 MWh	289,300 MWh
Levelized Cost of Energy (real)	11.9 ¢/kWh	12.4 ¢/kWh
Power Purchase Agreement price (year 1)	9.6 ¢/kWh	5.9 ¢/kWh

- Despite lesser generation, optimized dispatch produces greater value as indicated by a lower acceptable PPA price
- Matching CSP system design and dispatch to grid demand is essential



# Thank you!


[www.nrel.gov](http://www.nrel.gov)





# sCO<sub>2</sub> Cycle Development under STEP

DOE's "STEP" project will demonstrate a 10 MW<sub>e</sub> sCO<sub>2</sub> recompression cycle



Supercritical  
Transformational  
Electric  
Power

Image: Southwest Research Institute




# STEP Test Facility Attributes and Objectives

- 10 MW<sub>e</sub> sCO<sub>2</sub> recompression Brayton cycle
- Turbine inlet temperature of 700°C
- Demonstrate pathway towards an overall power cycle efficiency of 50% or greater
- Reconfigurable and can monitor and characterize primary components or subsystems (turbomachinery, heat exchangers, recuperators, bearings, seals, etc.)
- Demonstrate steady state, transient load following, and limited endurance operation.
- Capable of test campaigns to assess critical component degradation mechanisms to assess component life and cost



# sCO<sub>2</sub> Recompression Cycle

Design-point values from DOE-funded CSP Gen3 analysis report by Black & Veatch



Note: SunShot CSP plants are assumed to be dry cooled, so a higher design-point ambient temperature is likely.